

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0002593

Owner: Pittsburgh Corning Corporation
Address: 800 Presque Isle Drive, Pittsburgh, PA 15239

Continuing Authority: Same as above
Address: Same as above

Facility Name: Pittsburgh Corning Corporation
Address: 2700 West 16th Street, Sedalia, MO 65301

Legal Description: SW $\frac{1}{4}$, SW $\frac{1}{4}$, Sec. 5, T45N, R21W, Pettis County

Receiving Stream: Unnamed tributary to Brushy Creek (U)
First Classified Stream and ID: Brushy Creek (C) (00859)
USGS Basin & Sub-watershed No.: (10300101-040003)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 - Industry - SIC #3229
Non-contact cooling waters
Storm water run-off
Design flow is 7,000 gallons per day
Actual flow is 5,000 gallons per day

Outfalls #003 & #004
Grassed area - no longer needs
to be sampled

Outfall #002 - southeast corner of property
Stormwater/flow is dependent upon precipitation

Outfalls #005 & 006 - northwest
section of property
Stormwater/flow is dependent upon
precipitation

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

July 28, 2000
Effective Date

October 15, 2004
Modification Date

July 27, 2005
Expiration Date
MO 780-0041 (10-93)


Stephen M. Mahood, Director, Department of Natural Resources
Executive Secretary, Clean Water Commission


James R. Macy, Director, Kansas City Regional Office

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS					PAGE NUMBER 2 of 4	
					PERMIT NUMBER MO-0002593	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	MGD	*		*	once/quarter**	24 hr. estimate
Total Suspended Solids	mg/L	80		60	once/quarter**	grab
Oil & Grease	mg/L	15		10	once/quarter**	grab
Temperature (Note 1)	°F	95°		95°	once/quarter**	grab
pH - Units	SU	***		***	once/quarter**	grab
Algaecide (see Special Condition 7)	lbs./month	*		*	once/month****	
Total Residual Chlorine (Note 2)	mg/L	0.019		0.019	once/quarter**	grab
<u>Outfalls #002, #005 & #006</u>						
Flow	MGD	*		*	once/quarter**	24 hr. estimate
Total Suspended Solids	mg/L	80		60	once/quarter**	grab
Oil & Grease	mg/L	15		10	once/quarter**	grab
pH - Units	SU	***		***	once/quarter**	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE <u>January 28, 2005</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
B. STANDARD CONDITIONS						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Part I</u> STANDARD CONDITIONS DATED <u>October 1, 1980</u> and <u>August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- * Monitoring requirement only.
- ** Sample once per quarter during the months of January, April, July, and October.
- *** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.
- **** Measurements for algaecide must be taken once per month and reported in the amount of pounds of algaecide used in that month. The once per month measurements must be reported to the department in the quarterly discharge monitoring report.

Note 1 - Effluent shall not elevate or depress the temperature of the receiving stream beyond the mixing zone more than 5 degrees Fahrenheit. The stream temperature beyond the mixing zone shall not exceed 90 degrees Fahrenheit due to the effluent.

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

Note 2 - This permit contains a Total Residual Chlorine (TRC) limit.

- a. If the TRC limit in this permit is 0.019 mg/L or 0.2 mg/L, you must use an analytical method that has a quantification limit of no greater than 0.05 mg/L TRC. For reporting purposes on the discharge monitoring report (DMR), all analytical values below 0.05 mg/L shall be reported as "<quantlim." All analytical values at or above the quantification limit of 0.05 mg/L shall be reported as the measured value. The permittee shall report the quantification limit in the remarks section of the DMR.

The average monthly effluent values for TRC will be determined by assuming that analytical results below the quantification limit are equivalent to 0 mg/L when calculating the monthly average.

The daily effluent value will be considered equal to 0 mg/L if it is below the quantification limit.

- b. If the TRC limit in this permit is 1.0 mg/L; you must use an analytical method with a quantification limit between 0.2 and 0.5 mg/L. All analytical values below the quantification limit shall be reported as "<quantlim." All analytical values at or above the quantification limit shall be reported as the measured value.

The average monthly effluent values for TRC will be determined by assuming that analytical results below the quantification limit are equivalent to 0 mg/L when calculating the monthly average.

The daily effluent value will be considered equal to 0 mg/L if it is below the quantification limit.

- c. Do not chemically dechlorinate if it is not needed to meet the limits in your permit.
- d. If no chlorine was used in a given sampling period, an actual analysis is not necessary. Simply report as "0 mg/L" TRC.

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
- (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.

C. SPECIAL CONDITIONS (continued)

4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.

5. Report as no-discharge when a discharge does not occur during the report period.

6. Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria. General Criteria - The following water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:

- (a) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
- (b) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
- (c) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
- (d) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
- (e) There shall be no significant human health hazard from incidental contact with the water;
- (f) There shall be no acute toxicity to livestock or wildlife watering;
- (g) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
- (h) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

7. Any biocide discharge from any point source shall comply with the requirements of Federal Insecticide, Fungicide and Rodenticide Act, as amended (7 U.S.C. 136 et. seq.) and the use of such biocides shall be in a manner consistent with its label.

8. This permit may be reopened and modified or alternatively revoked and reissued to incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analyses, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the states water quality standards.